

RFB# 25-007 Troy University – Malone Hall Roof Recover

All information contained in this addendum shall supersede any previous contradicting information, or information otherwise not provided.

Bid Information:

1.01 The following are answers for questions that have been asked:

- Will this project have any warranties? – **No.**
- Can we get details for eave, gutters, coping cap, pipe penetrations, and walls? - **Transition Membrane down into gutter and termination bar into wood nailer 12” on center & sealant on T-Bar. Run new membrane up vertical services and install termination bar just beneath existing curb covers and metal flashings. Install skirt metal as needed.**
- Are we replacing the 182 LN of gutter of gutter, eave, fascia wood blocking and soffit only? – **Yes.**
- Are we replacing any existing roof or metal decking? – **No.**
- Do we include sales tax on the materials? – **No, this project is tax exempt.**
- The Materials for the project listed on the last page of the specifications to be purchased directly by Troy University directly. Will the cost for these need to be included in the bid price and then deducted out by change order or not, how will this be handled specifically? – **The bid is labor only, there is no need to include material price in the bid. The material will be purchased directly by the University.**